

NOTICE OF BOIL WATER ORDER RESCINDED (Acute Turbidity)

The Missouri Department of Natural Resources rescinded the Boil Water Order for Monroe City with public water system ID# MO2010538. The system is located at 109 Second Street in Monroe City, Monroe County, Missouri. Department officials rescinded the boil order on September 14th, 2016, after corrective actions were taken by the water system to provide adequate disinfection, remove possible contamination thru system wide flushing, and verification of test results from water samples collected on September 12th and September 13th, showed that the water is bacteriologically safe.

Department officials issued the order on July 25th, 2016, because of high turbidity levels in the finished water. Turbidity in finished water above the acute maximum contaminant level indicates that the treatment process has broken down and that disease causing organisms such as cryptosporidium or giardia may be present in the drinking water.

To assure that possible contamination is removed from customer plumbing all customers should flush all the water lines in their home, business, or building by operating all water faucets (both hot and cold), water appliances, and toilets. Any customer that notices colored or odorous water should report this to the water system listed below or to the department.

For additional information, call Mr. Jon Rogers at the city of Monroe City at (573) 735-4585) or the Missouri Department of Natural Resource's Northeast Regional Office at (660) 385-8000.

c: Public Drinking Water Branch