

## BID SPECIFICATIONS LOAD OF POWER POLES

The City of Monroe City is accepting bids for one (1) load of power poles that is comprised of:

- 35' class 4 pole – quantity of 35
- 40' class 4 pole – quantity of 8

Bidder may add to or deduct from the 40' poles in order to balance the load. All poles must be .60 CCA treated SYP, RUS/M-20 framing and WQC inspected. Poles must be delivered on a truck that has a self-unloader. All bids must include freight to Monroe City, Missouri. Questions concerning these specifications are to be addressed to Kerry Lee, Electric Department Manager at (573) 473-5209.

All bids must be submitted to the City of Monroe City at the above address by 2 pm, February 18, 2020. Fax bids are welcome at (573) 735-3314. The City of Monroe City reserves the right to reject any or all bids. In addition, the City reserves the right to select the bid which is in the best interest of the City and not necessarily the lowest bid.

Company's Bid: \$ \_\_\_\_\_

Delivery Date A.R.O.: \_\_\_\_\_

Name of Bidder: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_  
Signature of Company Representative

\_\_\_\_\_  
Date

\_\_\_\_\_  
Typed or Printed Name

\_\_\_\_\_  
Telephone Number

\_\_\_\_\_  
E-mail Address

\_\_\_\_\_  
Fax Number