

BID SPECIFICATIONS TRANSFORMERS

The City of Monroe City is accepting bids for eight (8) 25 KVA new or rebuilt pole mounted transformers that meet the below listed specifications:

- Dual Voltage 2400 x 7200 WYE
- 120/240 - Secondary Voltage

All bids must include delivery to the Power Plant in Monroe City. Questions concerning these specifications must be addressed to Kerry Lee at (573) 473-5209. All bids must be submitted to the City of Monroe City at the above address by 2 pm, February 18, 2020. Fax bids are welcome at (573) 735-3314. The City of Monroe City reserves the right to reject any or all bids. In addition, the City reserves the right to select the bid which is in the best interest of the City and not necessarily the lowest bid.

Company's Bid (New): \$ _____

Company's Bid (Rebuilt): \$ _____

Delivery Date A.R.O.: New _____ Rebuilt: _____

Name of Bidder: _____

Address: _____

Signature of Company Representative

Date

Typed or Printed Name

Telephone Number

Fax Number

Email Address

BID SPECIFICATIONS TRANSFORMERS

The City of Monroe City is accepting bids for four (4) 37.5 KVA new or rebuilt pole mounted transformers that meet the below listed specifications:

- Dual Voltage 2400 x 7200 WYE
- 120/240 - Secondary Voltage

All bids must include delivery to the Power Plant in Monroe City. Questions concerning these specifications must be addressed to Kerry Lee at (573) 473-5209. All bids must be submitted to the City of Monroe City at the above address by 2 pm, February 18, 2020. Fax bids are welcome at (573) 735-3314. The City of Monroe City reserves the right to reject any or all bids. In addition, the City reserves the right to select the bid which is in the best interest of the City and not necessarily the lowest bid.

Company's Bid (New): \$ _____

Company's Bid (Rebuilt): \$ _____

Delivery Date A.R.O.: New _____ Rebuilt: _____

Name of Bidder: _____

Address: _____

Signature of Company Representative

Date

Typed or Printed Name

Telephone Number

Fax Number

Email Address

BID SPECIFICATIONS TRANSFORMERS

The City of Monroe City is accepting bids for one (1) 25 KVA new or rebuilt pad mounted transformer that meets the below listed specifications:

- Dual Voltage 2400 x 7200 WYE
- 120/240 - Secondary Voltage

All bids must include delivery to the Power Plant in Monroe City. Questions concerning these specifications must be addressed to Kerry Lee at (573) 473-5209. All bids must be submitted to the City of Monroe City at the above address by 2 pm, February 18, 2020. Fax bids are welcome at (573) 735-3314. The City of Monroe City reserves the right to reject any or all bids. In addition, the City reserves the right to select the bid which is in the best interest of the City and not necessarily the lowest bid.

Company's Bid (New): \$ _____

Company's Bid (Rebuilt): \$ _____

Delivery Date A.R.O.: New _____ Rebuilt: _____

Name of Bidder: _____

Address: _____

Signature of Company Representative

Date

Typed or Printed Name

Telephone Number

Fax Number

Email Address